



## Declaration of Conformity

For the following equipment :

Product Name: Surge Protection Device

Model Designation: SPD-20HP-277S, SPD-20HP-480S

Identification:

	SPD-20HP-277S	SPD-20HP-480S
Max. Continuous Operating Voltage (Uc)	AC 320V	AC 510V
Voltage Protection Level (Up)	L-N:1000V L-G/PE:3800V N-G/PE:2900V	L-N:1600V L-G/PE:3800V N-G/PE:2900V
Test Class	II & III	II & III
Nominal Discharge Current (In)	10KA	10KA
Max. Discharge Current (Imax)	20KA	20KA
Protection Degree	IP66	IP66
Location Category	Indoor	Indoor
Temperature Range	-40°C to 75°C	-40°C to 75°C

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

### RoHS Directive (2011/65/EU)

### Low Voltage Directive (2014/35/EU) :

EN 61643-11:2012

SPD-20HP-277S

CB Report No: 3187362.50

SPD-20HP-480S

LVD Report No: 20180205

### Note:

This Declaration is effective from serial number 1812

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Alex Tsai /Director, Sales Dept :

(Name / Position)

(Signature)

Taiwan

(Place)

Apr.9th.2018

(Date)