



## **Declaration of Conformity**

For the following equipme	ent:					
Product Name: DALI-PW	M Signal Co	nverter				
Model Designation: DAP-	04					
is herewith confirmed to were applied:	comply with	the requirements se	et out in th	e Council [	Directive, th	ne following standards
RoHS Directive (201 Low Voltage Directive	•	EU) :				
EN61347-1:2008+A1+A2 EN61347-2-11:2001	•	TUV certificate	No : R50	271983		
Electromagnetic Com EMI (Electro-Magnetic In Conducted emission / R	nterference adiated emi	)	·			
Harmonic current	EN61000-	3-2:2006+A1:2009+	A2:2009			
Voltage flicker	EN61000-3-3: 2008					
EMS (Electro-Magnetic	Susceptibil	ity)				
EN61547: 2009						
ESD air	EN61000-	4-2:2009		Level 3	8KV	
ESD contact	EN61000-4-2:2009			Level 2	4KV	
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010			Level 2	3V/m	
EFT bursts	EN61000-4-4:2012			Level 2	1KV/5KH	z
Surge susceptibility	EN61000-4-5:2006			Level 2	1KV/Line	-Line
Surge susceptibility	EN61000-4-5:2006			Level 3	2KV/Line	-Earth
Conducted susceptibility	EN61000-	4-6:2009		Level 2	3V	
Magnetic field immunity	EN61000-	4-8:2010		Level 2	3A/m	
Voltage dip, interruption	EN61000-4-	-11:2004 >95% dip 0.5	periods 30	)% dip 25 pe	riods >95%	interruptions 250 periods
Note: Component power supply wiinstallation, the final equipme Tests above are only to be p For guidance on how to perfe	nt manufactur erformed with	ers must re-qualify EM0 LEDs.	C Directive of	n the comple	ete installatio	n again.
This Declaration is effective from serial number RB6xxxxxxx						
Person responsible for m	arking this d	eclaration:				
MEAN WELL Enterprises (Manufacturer Name)	Co., Ltd.					
No.28, Wuquan 3rd Rd., (Manufacturer Address)	Wugu Dist.,	New Taipei City 248	, Taiwan			11 1 -
Johnny Huang/Manager, Certific	cation Center:	John -	Ted Cher	ng/Director, S	ales Dept. :	Med Chang
(Name / Position) (Signature) (Name / Po						
Taiwan (Place)		Apr. 20th, 2016 (Date)				500 <b>0</b> 0