HYTRONIK

HIGH BAY RF WIRELESS MICROWAVE DALI SENSOR HMW39/RF + HC034RF


1. Technical Specifications

ΗĒ

HMW39/RF		
Product type	RF wireless microwave DALI sensor (tri-level control)	
Operating voltage	120~277VAC 50/60Hz	
Rated load	Maximum 20pcs DALI devices, Maximum 40mA	
Power consumption	< 1.5W	
Detection angle	360°	
Detection area (DxH)	10 x 12m (Maximum)	
Mounting height	12m (Maximum)	
Detection range	10% / 50% / 75% / 100%	
Hold time	2s / 30s / 1min / 5min / 10min / 15min / 20min / 30min	
Stand-by time	0s / 10s / 1min / 5min / 10min / 30min / 1h / +∞	
Stand-by dimming level	10% / 20% / 30% / 50%	
Daylight threshold	2 ~ 500Lux, Disable	
RF transmission distance	30 meters in the open area	
RF frequency	868MHz (FSK mode)	
Warming up time	20s	
Operating temperature	$-20^{\circ}C \sim +50^{\circ}C$	
IP rating	IP65	
HC034RF		
Product type	RF wireless receiver	

Product type	RF wireless receiver
Operating voltage	220-240V 50Hz
Rated load	Capacitive:400W; Resistive:1200W
IP rating	IP20

3. Rotary Switch for RF grouping



15 channels are available for fast grouping via rotary switch on both HMW39/RF and HC034RF. Simply selecting the same channel on each unit, the grouping is automatically completed.

Noted:channel "0" is not for fast grouping, and sensors can only be grouped by remote control.

4. Functions

4.1 Tri-level Control (Corridor Function)

Hytronik builds this function inside the motion sensor to achieve tri-level control, for some areas require a light change notice before switch-off.

It offers 3 levels of light: 100%-->dimmed light-->off; and 2 periods of selectable waiting time: motion hold-time and stand-by period: Selectable daylight threshold and freedom of detection area

4.2 Lux Off Function


The built-in daylight sensor can read ambient natural light and switch off the fixture automatically whenever artificial light is not required (natural light lux level exceeds daylight threshold). Note: if the stand-by time is preset at "+oo", the fixture never switches off even when natural light is sufficient.


2. Installation

/ Warnings:

- 1. Installation qualified engineer must be carried out by a in accordance with local regulations.
- 2. Disconnect supply before installing.
- 3. Install to a solid surface vibrations may cause mis-triggering.
- 4. Ensure environmental conditions are suitable for electronic equipment


A. Surface Mounting








C. Clamp Fixing








5. RF grouping



Short press "Learn/Erase" button on RC to the receiver to activate pairing mode, and the receiver unit will beep once every second for 3min. Note: up to 30 units can be paired.



Short press "Transmit" button on RC to the commander, the red indicator on commander unit will flash 3 times to send the transmission signal.


Upon receiving the transmission signal, the receiver unit will rapidly beep 3 times in 1s to indicate the success of pairing. One more short press on "Learn/Erase" button to the receiver unit to complete the pairing process, the receiver unit will quit the pairing mode.



Erase


Long press "Learn/Erase" button for 3s, the beeper on receiver unit rapidly beeps for 5s, all commands it has received before will be erased.







WWW.HYTRONIK.COM

6. Wiring Diagram





8. Description of the Button Functions (remote control HRC-11)



HYTRONIK®

HMW39/RF-20170510-A1

Permanent ON/OFF [button ①] Press button ①, to select permanent ON or permanent OFF mode. * Press button ②/④ to resume automatic operation.	Detection range [zone (®)] Press buttons in zone (®) to set detection range at 100% / 75% / 50% / 10%.	Dual tech & RF mode [zone ④] 1. HF, PIR, HF-PIR, HF/PIR are disabled. 2. Short press button "Learn/Erase" to activate pairing mode on all		
RESET[button ②] Press button ②, all settings go back to the rotary switch settings.	Note: Disabled for HC034RF. Daylight threshold [zone ()]	receiver (slaw) units to be paired. Note:up to 30 units can be paired. 3. Short press button "Transmit" at the commander unit(master), the LED will flash 3 times to indicate the transmission signal has been sent. The receiver units will radjud beep 3 times in 1s to indicate the success of pairing. 4. Long press "Learn/Erase" button for 3s, and the receiver unit clears all commands it has received before. 5. Press button RX100%, the light on receiver unit is 100% on upon receiving RF on signal; "Press" RX STBY% button, the light(s) goes to presset stand-by dimming level directly.		
Shift [button ③] Press button ③, the LED on the top left corner will flash to indicate mode selection. All values / settings in RED are in valid for 20 seconds.	Press buttons in zone () to set the daylight sensor at 2Lux / 10Lux / 50Lux / 100Lux / 300Lux / 500Lux or Disable. Note: 1. To set daylight sensor at 100Lux / 300 Lux / 500Lux, press button () Shift at first. 2. Disabled for HC034RF;			
Auto Mode [button ③] Press button ④ to initiate automatic mode. The sensor starts working and all settings remain as before the light was switched O/VOFF. Note: the function of semi-auto is disabled.	Ambient daylight threshold [button ()] 1. Press button ()) Shift, the red LED is on for indication. 2. Press button ()), the ambient lux level is sampled and set as the new daylight threshold.			
Power output [button ⑤] Press button ⑤, the light output shifts between 80% and 100%. Note: the function of "Sensor off" and "Twilight" are disabled. Brightness +/- [button ⑥] Press button ⑥ to adjust the light brightness between 10%-100%. Scene prog. [zone ⑦] (One-key-commissioning) 1. Press button "start" to program. 2. Select the buttons in ⑧ "Detaction range", ⑧/ ⑨ "Daylight threshold", ⑪ "Hold time" (⑳ "Stand-by time", ⑳ "Stand-by dimming level" to set all parameters. 3. Press button "Memory" to save all the settings programmed in the remote control. 4. Press button "Apply" to sate the settings to each sensor unit(s). For example, to pre-set detection range 100%, daylight threshold "@indmin, teah-by time +∞, stand-by dimming level 30%, steps should be: Press button. @bale, hold time #in, stand-by time +∞, stand-by dimming level 30%, steps should be: Press button. @bale, hold time #in, stand-by Dy by pointing to the sensor unit(s) and pressing ⑦ Apply, all settings are passed on the sensor(s).	Hold time [zone ①] Press buttons in zone ① to set the hold time at 2s / 30s / 1min / 5min / 10min / 15min / 20min / 30min. Note: 1.0 set Hold-time at 30s / 5min / 15min / 30min, press button@Shift at first. .2 zs is for test purpose only, stand-by period and daylight sensor settings are disabled in this mode. "To exit from Test mode, press button ② or any button in zone ③. Stand-by time [zone ③] Press buttons in zone ③ to set the stand-by period at 0s / 10s / timin / 5min / 10min / 30min / 1n / +∞. Note: -0s' means on/off control: ++∞' means bi-level control, 100% on when motion detected, and remains at the stand-by dimming level when no presence after hold-time. Stand-by dimming level [zone ③] Press buttons in zone ③ to set the stand-by dimming level at 10% / 20% / 30% / 50%.			
9. Trouble Shooting				

MALFUNCTION CAUSE REMEDY CAUSE REMEDY Incorrect daylight threshold setting Adjust daylight threshold setting Faulty fixture Replace fixture The fixture does not light up No power supply Check power to sensor Detection zone not targeted Check detection area setting The fixture is always on Continued movement in the detection zone Check detection area setting Sudden change in temperature due to weather (wind, rain, snow) The fixture is on when it should not Adjust zone, change installation site or air expelled from fans, open windows

